

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7258-1591:123 Page 1 of 1

CATEGORY: Combination Ionization/Photoelectric Smoke Detector

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Model SIGA-IPHS combination ionization/photoelectric smoke detector. Unit has built in heat sensor. Refer to listee's data sheet for detailed model descriptions and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an combination ionization/photoelectric smoke detector for use with listee's separately listed base (CSFM Listing No. 7300-1591:120) and compatible fire alarm control units.

NOTE:

1. NOT INTENDED TO BE USED IN LIEU OF REQUIRED HEAT DETECTORS.
2. Formerly 7258-1388:183

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JANUARY 16, 2003

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager